

# 別紙 4 3 計画給水人口・計画給水量

## 夕張市（全体）推計結果

夕張市(全体)			推計値																						
			H21	H22	H23	H24	H25	H26	H27	H28	H29	H30	H31	H32	H33	H34	H35	H36	H37	H38	H39	H40	H41	H42	
年度			2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	
地域内人口 (人)			11,663	11,351	11,044	10,746	10,455	10,173	9,898	9,605	9,320	9,043	8,775	8,515	8,244	7,982	7,729	7,483	7,245	7,008	6,778	6,556	6,341	6,133	
給水区域内人口 (人)			11,663	11,351	11,044	10,746	10,455	10,173	9,898	9,605	9,320	9,043	8,775	8,515	8,244	7,982	7,729	7,483	7,245	7,008	6,778	6,556	6,341	6,133	
給水人口 (人)			11,663	11,351	11,044	10,746	10,455	10,173	9,898	9,605	9,320	9,043	8,775	8,515	8,244	7,982	7,729	7,483	7,245	7,008	6,778	6,556	6,341	6,133	
給水普及率 (%)			100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	
用途別水量	生活用	一人一日平均使用水量 (L/人/日)	157	157	157	157	157	157	157	157	157	157	157	157	157	157	157	157	157	157	157	157	157	157	
		一日平均使用水量 (m³/日)	1,829	1,780	1,732	1,682	1,640	1,595	1,553	1,506	1,462	1,418	1,376	1,335	1,293	1,251	1,212	1,174	1,136	1,099	1,063	1,028	995	962	
	業務用	一日平均使用水量 (m³/日)	995	964	934	905	881	856	833	810	789	767	749	732	713	696	681	664	649	635	620	608	596	582	
		工場用 一日平均使用水量 (m³/日)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	その他	一日平均使用水量 (m³/日)	654	654	654	654	654	654	654	654	654	654	654	654	654	654	654	654	654	654	654	654	654	654	654
		小計 (m³/日)	3,478	3,398	3,320	3,241	3,175	3,105	3,040	2,970	2,905	2,839	2,779	2,721	2,660	2,601	2,547	2,492	2,439	2,388	2,337	2,290	2,245	2,198	
	無収水量 (m³/日)		434	426	414	406	397	388	380	372	363	355	347	341	333	326	319	312	305	299	292	287	281	275	
	無効水量 (m³/日)		435	424	416	405	397	388	380	371	363	355	348	340	333	325	318	311	305	298	292	286	281	275	
	一日平均給水量 (m³/日)			4,347	4,248	4,150	4,052	3,969	3,881	3,800	3,713	3,631	3,549	3,474	3,402	3,326	3,252	3,184	3,115	3,049	2,985	2,921	2,863	2,807	2,748
	一人一日平均給水量 (L/人/日)			373	374	376	377	380	382	384	387	390	392	396	400	403	407	412	416	421	426	431	437	443	448
一日最大給水量 (m³/日)			7,508	7,336	7,167	6,997	6,854	6,703	6,564	6,413	6,273	6,131	6,003	5,880	5,750	5,624	5,508	5,390	5,277	5,168	5,059	4,961	4,864	4,764	
一人一日最大給水量 (L/人/日)			644	646	649	651	656	659	663	668	673	678	684	691	697	705	713	720	728	737	746	757	767	777	
有収率 (%)			80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	
有効率 (%)			90.0	90.0	90.0	90.0	90.0	90.0	90.0	90.0	90.0	90.0	90.0	90.0	90.0	90.0	90.0	90.0	90.0	90.0	90.0	90.0	90.0	90.0	
負荷率 (%)			57.9	57.9	57.9	57.9	57.9	57.9	57.9	57.9	57.9	57.9	57.9	57.9	57.8	57.8	57.8	57.8	57.8	57.8	57.7	57.7	57.7	57.7	



